



Ref. Certif. No.

CN30196-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Fuse-links for the protection of semiconductor devices

Name and address of the applicant
Nom et adresse du demandeur

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province, P.R.China

Name and address of the manufacturer
Nom et adresse du fabricant

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province, P.R.China

Name and address of the factory
Nome et adresse de l'usine

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Economic Development Zone, Yueqing,
Zhejiang 325600 P.R. China

Note: When more than one factory, please report on page 2
Note: Lorsque plus d'une usinem, veuillez utiliser la 2^{me} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Un: AC690V;In: 16A, 20A, 25A, 32A, 35A, 40A, 45A, 50A,
55A, 63A, 70A, 75A, 80A, 85A, 90A, 100A; Rated breaking
capacity: 50kA;Breaking range and utilization category: aR

Trademark (if any)
Marque de fabrique (si elle existe)

MIRO

Model / Type Ref.
Ref. De type

RGS4□□/□

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{me} page)

Original CB is CN30196 , dated 2014-04-25. This
modification is to update standard.

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION EDITION

IEC 60269-1:2006 (4th Edition)+ AMD 1:2009;IEC
60269-4:2009(5th Edition) + AMD 1:2012

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitre partie de ce Certificat

00901-CB2016CQC-073891

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: Aug.03,2017

Signature: Wang Kejiao