



Ref. Certif. No.

CN45562

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fuse-disconnector

Name and address of the applicant

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Yueqing Economic Development Zone,
Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Yueqing Economic Development Zone,
Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Economic Development Zone, Yueqing,
Zhejiang 325600 P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:8kV;Ui: 1000V;DC-20B, DC-PV0;lth: 30A;Ue/Ie:
DC1000V/30A;Iq: 50kA;1P appearance;IP20

Trademark (if any)

MiRO

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PVH-30,PVH-30(X)

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 (5th Edition) + AMD1:2010 +
AMD2:2014;IEC 60947-3:2008(3rd Edition) + AMD 1:2012 +
AMD 2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2018CQC-082191

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.26,2018

Signature:

Lu Mei



CB 0049697